



DEPARTMENT OF ENVIRONMENT AND CONSERVATION
DIVISION OF WATER POLLUTION CONTROL
6TH FLOOR, L&C ANNEX, 401 CHURCH ST. NASHVILLE, TN 37243

NOTICE OF INTENT (NOI)
for discharges of treated groundwater associated with
UNDERGROUND STORAGE TANK (UST) REMEDIATION

This application is for: ☒ New Permit ☐ Permit Reissuance ☐ Permit Modification

(If this NOI is submitted for Permit Modification provide the existing permit tracking number: TNG83)

Site Name: BY-LO #1	County: GRAINGER
Street Address or Location: 1245 BROADWAY DRIVE, BEAN STATION, TN	*Latitude: 36.323778
	*Longitude: -83.280865
UST Site ID Number: 2-290013	Attach a site location (topographic) map <input checked="" type="checkbox"/> Map attached

Owner or Operator: (the person or legal entity which controls site's operation; this may or may not be the same as the site name or the official contact name) COFFMAN OIL COMPANY				
1	Official Contact Person Name: (individual responsible for a site) MR. MITCH ROBINSON		Title or Position: PRESIDENT	
	Mailing Address: P.O. BOX 1241		City: MORRISTOWN	State: TN
	Phone: (423) 586-0681		Zip: 37814-1241	
	E-mail:			
2	Local Contact Person Name: (if appropriate, write "same as #1") JIM WINGFIELD		Title or Position: President-Wingfield Environmental, Inc.	
	Site Address: (this may or may not be the same as street address) PO BOX 8957		Site City: GRAY	State: TN
	Phone: 423-323-7969		Zip: 37615	
	E-mail: jimmy@wingfieldenviro.com			

Write in the box (to the right) or circle the number (above) to indicate where to send correspondence:

2

UST REMEDIATION FACILITY DESCRIPTION

Treated groundwater from site enters following stream(s) and/or lake(s): (for each outfall, give names and stream miles) Enters Ditch line that flows ~100 ft. into unnamed Tributary that flows ~1,000 ft into Cherokee Lake near Mile 79.	No. of outfalls: 1
List type of product(s) currently or previously stored in tanks located at the site: Gasoline	
Description of contamination, assessment study, extent of contamination, etc. Attach additional pages if necessary. Gasoline contamination above UST levels. See attached Corrective Action Plan Summary.	
Description and design capacity of treatment process and facilities. Liquid ring pump extracts groundwater then goes through oil/water separator, then air stripper treating less than 5 gal/min.	
Select discharge type (continuous means more than 4 days at a time): <input type="checkbox"/> Continuous <input checked="" type="checkbox"/> Intermittent	
Expected starting date for groundwater treatment, and estimated life of remediation project: June/July 2011 estimated starting with 2-4 yr estimated remediation project.	

CERTIFICATION AND SIGNATURE

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.			
C. Mitch Robinson	President		6/27/11
Printed Name	Official Title	Signature	Date

STATE USE ONLY

Received Date	Reviewer	EFO	NOC Date	Tracking No. 0166 TNG83
---------------	----------	-----	----------	-----------------------------------

RECEIVED

JUN 30 2011

Submit the original of the completed and signed form to:

UST NOI Processing
Tennessee Division of Water Pollution Control
6th Floor L&C Annex, 401 Church Street
Nashville, TN 37243

(continued)

RD-As 2399 and 2400



DEPARTMENT OF ENVIRONMENT AND CONSERVATION
DIVISION OF WATER POLLUTION CONTROL
6TH FLOOR, L&C ANNEX, 401 CHURCH ST. NASHVILLE, TN 37243

NOTICE OF INTENT (NOI)

for discharges of treated groundwater associated with

UNDERGROUND STORAGE TANK (UST) REMEDIATION

	Impaired Receiving Stream	High Quality Water	T & E Aquatic Fauna
--	---------------------------	--------------------	---------------------

RECEIVED

JUN 30 2011

FOR DIVISION OF WATER
POLLUTION CONTROL

Submit the original of the completed and signed form to:

UST NOI Processing
Tennessee Division of Water Pollution Control
6th Floor L&C Annex, 401 Church Street
Nashville, TN 37243